

**ADDENDUM NO. TWO**

**JOB NAME:** Knox Co Parks Electrical Rehabilitation

**PROJECT NUMBER:** 23-800-291-1

**DATE OF ADDENDUM:** 03/26/2024



---

**Dustin Barth, P.E.**  
**Indiana Registration No. 12200401**

**THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND IS ISSUED IN ACCORDANCE WITH THE INSTRUCTIONS TO BIDDERS. ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY SIGNING THE ADDENDUM ACKNOWLEDGEMENT SECTION OF YOUR PROPOSAL.**

**RFI's:**

1. On PB-1, 2, 3, 4, we can only do these in a panelboard configuration with 25KAIC Series rating. If we fully rate, we must go to an I-Line which is going to blow pricing out of the water. Do you know if the engineer will accept series rating?
  - a. This is acceptable.
2. The panels are listed with integral SPDs, but no specification or size indicated for them. I can provide with a minimum or recommended level....suggest minimum at 80KA and recommended at 120KA.
  - a. Providing recommendation is preferred.

END OF ADDENDUM 2