



ADDENDUM NO. 01

2024.12.23

01

FOR:

Evidence Room for
City of Southgate Police Department
122 Electric Ave
Southgate, Kentucky 41071

PREPARED BY:

Emboss Design ^{PSC}
906 Monmouth Street
Newport Kentucky, 41071
P: 859.578.6002

NOTE: The following additions, deletions, corrections, changes and/or clarifications to the Contract Documents (Drawings) for the above referenced project shall hereby be incorporated into the work described and their effect on the contract cost shall be included in the contractor's bid. Bidders shall verify this fact by indicating receipt of this Addendum in their bids.

1.0: PRE-BID MEETING

1.1: See attached sign-in list for attendees at the pre-bid meeting conducted on December 20, 2024.

2.0: GENERAL

2.1: General Contractor shall coordinate installation of Datum Storage system with Owner's vendor prior to beginning work

2.2: As clarification, wall type with line hatch is to have one layer of 5/8" type 'X' impact resistant gypsum board on both sides of wall.

2.3: Glass block to be frosted. Final selection to be made by Owner or Architect.

2.4: As clarification, there is no requirement for a Performance & Payment Bond

2.5: Patch all fastener holes in structural glazed tile walls prior to painting

2.6: Patch holes in plaster ceiling prior to painting. Assume approximately 6 sf total across all miscellaneous holes.

3.0 ATTACHMENTS:

- Pre-bid Sign-in list

END OF ADDENDUM NO. 1

