

Addendum 3



Date: 01/14/2025

Project Name: Lee L. Driver Middle School HVAC Upgrades

Project #: 24093

Contractor Questions:

Q1: Will Pro Press fittings be acceptable?

A1: *Yes, please refer to specification 23 21 13 – 1 – 2.01.*

Q2: If we run into an area where sprinkler lines are needing to be moved, will this be done with a change order or will it need to be included in our base bid?

A2: *Any sprinkler head and branch relocation required shall be included in the Contractor's bid price. If relocation of mains and submains 2" or larger is required due to field routing conditions, cost of relocation will be Change Order.*

Submitted By: Tyler Vest